

The Manager,
S.D. INTERNATIONAL SCHOOL
SECTOR- 06, U/E, SECTOR 6 URBAN ESTATE, PANIPAT
HARYANA, PANIPAT, 132103
(M: 0180-00000000)

Dated: 19/07/2024

SUBJECT: -FRESH AFFILIATION UP TO SENIOR SECONDARY LEVEL-regarding.
Ref : Application No.: - SS-00052-2526 Dated:13/05/2024

Sir/Madam,

This is with reference to school application on the subject cited above, I am directed to convey approval of the Board for Fresh Affiliation up to Senior Secondary Level as per details given below :

Affiliation No used as User ID for both OASIS and LOC/Registration System	532134
School No	42166
* Password for OASIS and LOC/Registration Systems is same as that used for Affiliation Application.	
Affiliated for	Senior Secondary School Examination Class 1 to 12
Category	Fresh Affiliation
Period of affiliation	01.04.2025 to 31.03.2030
Year and Month From which admission can be taken in Class-IX/XI	1 April, 2025
Year and Month in which first batch of Class-X/XII will appear in board examinations	1 April, 2027

Sl. No.	The school is directed to ensure that :
1	The total number of sections of Bal vatika shall be restricted to 5 Bal Vatika I, II & III). The total number of sections from classes 1 to XII shall be restricted to 27. The total number of sections taken together for classes XI and XII should not be more than 1/3 of the number of section allowed including Bal Vtika. Any further increase shall require prior permission of the Board and shall be subject to compliance with the affiliation Bye laws and availability of rooms of >500 sq ft dimensions.
2	Separate CwSN toilets for boys and girls are not seen on every floor. Thus, the school is required to construct the CwSN toilets separately for boys and girls on each floor with sufficient space for easy movement of the wheelchair as well as handrail on both side of toilet seat (fixed and movable) and proper permanent signage (on the cubicle indicating the floor number) as per norms of RPwD Act and board's guidelines within 03 months and submit the compliance.
3	Composite lab does not have permanent workstations separately for Physics, Chemistry and Biology sections with appropriate fixture like sinks with water connection, piped gas supply on the demonstration tables, no seating facilities, no storage facilities. Some equipment are seen placed adjacent to side walls which is not appropriate for conduct of practical. Chemistry and Biology lab is seen understocked and there is no storage facility. Hence the school is directed to upgrade the labs as per SoP issued by the Board and submit the compliance within 3 months.
4	Separate reading space is not seen the library. Hence the school is directed to upgrade the library as per SoP issued by the Board and submit the compliance within 3 months.
5	The school shall conduct training of its teachers with CoE Panchkula within 3 months and submit the compliance.

Compliance of the above mentioned points shall be submitted within 03 months on the SARAS Portal. Failure to comply within the prescribed time shall invite financial penalty @ Rs. 50,000/- every month until compliance is submitted and shall debar the school from filling the registration and LOC of students class IX to class XII, as the case may be.